

www.bkte.pl

Product Information

Underground metal plinth BKT RAL 7035

No. Card PI_110A40xx_01.16





Application

• Positioning of the cabinet in the ground

Standards

- · RoHS—Restriction of the use of certain hazardous substances in electrical and elektronic equipment
- EN ISO 9001:2008—Quality management
- EN ISO 14001:2004—Enviromental management

Construction

- Base equipped with crossbars situated under foam cable glands in the cabinet floor, for fixing pipes intended for leading cables into cabinet
- 4 or 6 screws included in set , for mounting cabinet to the plinth
- Embossment at front, back and on side (about 50mm from the top) determining depthof placing the base in the ground.

This Specification is the property of BKT Elektronik and is protected by copyright law. Every effort is made to ensure that accuracy of this information. However, BKT Elektronik cannot warrant that the specification is error-free, nor can it accept responsibilities for errors. The information contained in this specification is subject to change without notice and does not represent a commitment on final product.



www.bkte.pl

Product Information

Underground metal plinth BKT RAL 7035

No. Card PI_110A40xx_01.16

Features

- Welded structure with reinforcing crossbars fixed with screws
- Material uses : 1,5mm thick stainless steel, painted to RAL7035

Optional accessories

- 110A15xx—BKT 19" outdoor cabinet IP55 RAL7035 (aluminium, double wall)
- 110A16xx— BKT 19" outdoor cabinet IP55 RAL7035 (aluminium, single wall)

Performance/Variants

| Туре | Width (mm) | Depth (mm) | Height (mm) |
|----------|------------|------------|-------------|
| 110A4000 | 800 | 450 | 600 |
| 110A4001 | 1200 | 450 | 600 |
| 110A4002 | 800 | 800 | 600 |
| 110A4003 | 1200 | 800 | 600 |